



415 N. McKinley, 140 Plaza West
Little Rock, AR 72205-3020
501-614-3356 • Fax: (501) 666-0376
John E. Mills
Manager, Tariff Studies

December 20, 2006

Mr. Alan Derichsweiler
Western Farmers Electric Cooperative
Post Office Box 429
Anadarko, OK 73005

RE: Transmission System Upgrade Authorization for Transmission Service Requests 1183948

Dear Mr. Derichsweiler:

Southwest Power Pool has received Network Integrated Transmission Service agreements executed by Oklahoma Gas and Electric Company for the above noted transmission service request. In the facility study conducted in the assessment of this request, SPP concluded that system upgrades are required on the WFEC transmission system as detailed in Aggregate Facility Study SPP-2006-AG1-AFS-4. SPP authorizes WFEC to construct those upgrades to the transmission system concluded in the Facility Study to be necessary to provide the requested transmission service.

SPP authorizes WFEC to upgrade terminal equipment at FPL Switch and Mooreland 138kV Substations required by June 1, 2008.

WFEC shall submit certificate of commercial operation of the listed Network Upgrade to SPP as soon as the upgrade is completed and in service. Please provide SPP with the actual costs of these upgrades as soon as possible after the completion of construction. This will permit SPP to true up billing to actual costs on a timely basis.

Consistent with Section 20.1 of the SPP Tariff, please keep SPP advised of any inability on WFEC's part to complete the upgrades in time to provide the committed service. Provide SPP with the construction schedule supporting the required upgrade noted above within 30 days of receipt of this Transmission System Upgrade Authorization letter. Based on this schedule, SPP will require quarterly updates to the schedule status.

Don't hesitate to contact me if you have questions.

Sincerely,

A handwritten signature in blue ink that reads 'John E. Mills'.

John E. Mills
Manager, Tariff Studies

cc: P. Bourne, L. Dillahunty, J. Caspary, J. Rooker