

## SPP Notification to Construct

February 8, 2010

SPP-NTC-20074

Mr. Jeff Knottek  
City Utilities of Springfield  
301 East Central  
Springfield, MO 65801-0551

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Knottek,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachment O, Section VIII, of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing City Utilities of Springfield, as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade.

On January 26, 2010, the Southwest Power Pool ("SPP") Board of Directors approved the Network Upgrade listed below that is no longer needed for reliability to be withdrawn.

### **Withdrawal of Upgrade**

**Previous NTC number:** 20011

**Previous NTC issue Date:** 2/13/2008

**Project ID:** 441

**Project Name:** Line - Kickapoo - Sunset 69 kV

**Network Upgrade ID:** 10572

**Network Upgrade Description:** Reconductor Kickapoo - Sunset 69 kV line from 636 ACSR to 762.8 ACSS/TW.

**Reason For Change:** Withdraw. The Kickapoo - Sunset 69 kV did not overload using the 2009 STEP models with the new load forecast.

### **Withdrawal of Network Upgrade**


City Utilities of Springfield has been made aware of this Network Upgrade withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this

Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Bruce A. Rew".

Bruce Rew  
Vice President, Engineering  
Phone (501) 614-3214 • Fax: (501) 821-3198 • [BRew@spp.org](mailto:BRew@spp.org)

cc: Carl Monroe, Les Dilahunty, Pat Bourne, Jay Caspary, Keith Tynes, John Mills,  
[SPPprojecttracking@spp.org](mailto:SPPprojecttracking@spp.org), John Chamberlin