

Req.	Applicability	Effective Date	
		Jurisdictions where Regulatory Approval is Required	Date
R1	Each Transmission Owner, Generator Owner and Distribution Provider with transmission lines operating at 200 kV and above and transformers with low voltage terminals connected at 200 kV and above, except as noted below.	First day of the first calendar quarter, after applicable regulatory approvals	7-1-12
	<ul style="list-style-type: none"> For Requirement R1, criterion 10.1, to set transformer fault protection relays on transmission lines terminated only with a transformer such that the protection settings do not expose the transformer to fault level and duration that exceeds its mechanical withstand capability 	First day of the first calendar quarter 12 months after applicable regulatory approvals	7-1-13
	<ul style="list-style-type: none"> For supervisory elements as described in PRC-023-2 - Attachment A, Section 1.6 	First day of the first calendar quarter 24 months after applicable regulatory approvals	7-1-14
	<ul style="list-style-type: none"> For switch-on-to-fault schemes as described in PRC-023-2 - Attachment A, Section 1.3 	Later of the first day of the first calendar quarter after applicable regulatory approvals of PRC-023-2 or the first day of the first calendar quarter 39 months following applicable regulatory approvals of PRC-023-1 (October 1, 2013)	7-1-12 (ver. 2), or 10-1-13 (ver. 1) 10-1-13 is the later date.
	Each Transmission Owner, Generator Owner, and Distribution Provider with circuits identified by the Planning Coordinator pursuant to Requirement R6	Later of the first day of the first calendar quarter 39 months following notification by the Planning Coordinator of a circuit's inclusion on a	4-1-17 or 1-1-XX (XX is the year PC's planning study identifies circuit meeting criteria in Attachment B). See next page for examples.

Table taken from Reliability Standard PRC-023-2

Requirement	Applicability	Effective Date	
		Jurisdictions where Regulatory Approval is Required	DATE
		list of circuits subject to PRC-023-2 per application of Attachment B, or the first day of the first calendar year in which any criterion in Attachment B applies, unless the Planning Coordinator removes the circuit from the list before the applicable effective date	<p>Example: PC's study finds circuit meets criteria in 2019. Planning horizon is greater than 39 months from notification. Effective date is 1-1-19.</p> <p>Example: If PC's study finds circuit meets criteria in 2014. Effective date is 39 months from notification or 4-1-17.</p>
R2 and R3	Each Transmission Owner, Generator Owner, and Distribution Provider with transmission lines operating at 200 kV and above and transformers with low voltage terminals connected at 200 kV and above	First day of the first calendar quarter after applicable regulatory approvals	7-1-12
	Each Transmission Owner, Generator Owner, and Distribution Provider with circuits identified by the Planning Coordinator pursuant to Requirement R6	Later of the first day of the first calendar quarter 39 months following notification by the Planning Coordinator of a circuit's inclusion on a list of circuits subject to PRC-023-2 per application of Attachment B, or the first day of the first calendar year in which any criterion in Attachment B applies, unless the Planning Coordinator removes the circuit from the list before the applicable effective date	<p>4-1-17 or 1-1-XX (XX is the year PC's planning study identifies circuit meeting criteria in Attachment B).</p> <p>Example: PC's study finds circuit meets criteria in 2019. Planning horizon is greater than 39 months from notification. Effective date is 1-1-19.</p> <p>Example: If PC's study finds circuit meets criteria in 2014. Effective date is 39 months from notification or 4-1-17.</p>

Table taken from Reliability Standard PRC-023-2

Requirement	Applicability	Effective Date	
		Jurisdictions where Regulatory Approval is Required	DATE
R4	Each Transmission Owner, Generator Owner, and Distribution Provider that chooses to use Requirement R1 criterion 2 as the basis for verifying transmission line relay loadability	First day of the first calendar quarter six months after applicable regulatory approvals	1-1-13
R5	Each Transmission Owner, Generator Owner, and Distribution Provider that sets transmission line relays according to Requirement R1 criterion 12	First day of the first calendar quarter six months after applicable regulatory approvals	1-1-13
R6	Each Planning Coordinator shall conduct an assessment by applying the criteria in Attachment B to determine the circuits in its Planning Coordinator area for which Transmission Owners, Generator Owners, and Distribution Providers must comply with Requirements R1 through R5	First day of the first calendar quarter 18 months after applicable regulatory approvals	1-1-14

Table taken from Reliability Standard PRC-023-2