

SPP-NTC-200405

**SPP
Notification to Construct**

August 17, 2016

Mr. Nathan McNeil
Westar Energy, Inc.
P.O. Box 889
Topeka, KS 66601

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. McNeil,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") to Westar Energy, Inc. ("WR"), as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On July 26, 2016, the SPP Board of Directors approved the Network Upgrade(s) listed below to be withdrawn.

Withdrawal of Upgrades

Previous NTC Number: 200345

Previous NTC Issue Date: 6/30/2015

Project ID: 756

Project Name: XFR - Baldwin Creek 230/115 kV Ckt 1 Transformer

Network Upgrade ID: 10998

Network Upgrade Name: Baldwin Creek 230/115 kV Ckt 1 Transformer

Network Upgrade Description: Tap the Lawrence Hill - Swissvale 230 kV line into the Baldwin Creek 115 kV substation. Install a new 230/115 kV transformer at Baldwin Creek.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2016 ITPNT.

Withdrawal of Network Upgrade


This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

SPP-NTC-200405

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell
Vice President, Engineering
Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
John Olsen - WR