

SPP Notification to Construct

October 6, 2016

Mr. Nathan McNeil
Westar Energy, Inc.
P.O. Box 889
Topeka, KS 66601

RE: Notification to Construct for Transmission Service Request resulting from Aggregate Transmission Service Study SPP-2009-AGP2-AFS-6

Dear Mr. McNeil,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Westar Energy, Inc. ("WR"), as the Designated Transmission Owner, to construct the Network Upgrades.

On October 4, 2016, SPP concluded that the Network Upgrade(s) listed below should be withdrawn.

Withdrawal of Upgrades

Previous NTC Number: 20140

Previous NTC Issue Date: 5/27/2011

Project ID: 30326

Project Name: Line - Clay Center Switching Station - TC Riley 115 kV Ckt 1

Network Upgrade ID: 50372

Network Upgrade Name: Clay Center Switching Station - TC Riley 115 kV Ckt 1

Network Upgrade Description: Build 6.7-mile Clay Center Switching Station to TC Riley 115 kV line with Single 1192.5 kcmil ACSR (Bunting).

Reason for Change: SPP determined the Network Upgrade is no longer required due to the Aggregate Study re-evaluation process.

Previous NTC Number: 20140

Previous NTC Issue Date: 5/27/2011

Project ID: 30328

Project Name: Sub - TC Riley 115 kV

Network Upgrade ID: 50374

Network Upgrade Name: TC RILEY 115 kV

Network Upgrade Description: Install a 2000 Amp bus system, GOAB switches, metering and communication systems.

Reason for Change: SPP determined the Network Upgrade is no longer required due to the Aggregate Study re-evaluation process.

Withdrawal of Network Upgrade

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this project(s) and nothing in this letter shall carry such terms and conditions.

Don't hesitate to contact me if you have questions or comments about these requests. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas – SPP
Jay Caspary – SPP
John Olsen - WR