

SPP-NTC-200415

**iSPP
Notification to Construct**

November 14, 2016

Mr. Wayman Smith
American Electric Power
212 E. 6th St.
Tulsa, OK 74119

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Smith,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") to American Electric Power ("AEP") as agent for Public Service Company of Oklahoma, Southwestern Electric Power Company, and AEP Oklahoma Transmission Company, as the Designated Transmission Owner, as indicated below with regard to the following Network Upgrade(s).

On October 25, 2016, the SPP Board of Directors approved the Network Upgrade(s) listed below to be withdrawn.

Withdrawal of Upgrades

Previous NTC Number: 200314

Previous NTC Issue Date: 2/18/2015

Project ID: 30526

Project Name: Line - Hobart - Roosevelt Tap - Snyder 69 kV Ckt 1 Rebuild

Network Upgrade ID: 50657

Network Upgrade Name: Hobart - Roosevelt Tap 69 kV Ckt 1 Rebuild

Network Upgrade Description: Rebuild 10-mile 69 kV line from Hobart to Roosevelt Tap. Upgrade jumpers, switches, CTs, and relay settings at Hobart.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2016 ITPNT.

Network Upgrade ID: 50658

Network Upgrade Name: Roosevelt Tap - Snyder 69 kV Ckt 1 Rebuild

Network Upgrade Description: Rebuild 18.7-mile 69 kV line from Roosevelt Tap to

SPP-NTC-200415

Snyder. Upgrade jumpers, switches, CTs, and relay settings at Snyder.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2016 ITPNT.

Withdrawal of Network Upgrade

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell
Vice President, Engineering
Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Jay Caspary - SPP
Bob Bradish - AEP
Paul Johnson - AEP
Richard Ross - AEP
Brian Johnson - AEP
Scott Rainbolt - AEP
Matt McGee - AEP