

SPP-NTC-200464

**SPP
Notification to Construct**

September 21, 2017

Mr. Derek Brown
Westar Energy, Inc.
P.O. Box 889
Topeka, KS 66601

RE: Withdrawal of Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Brown,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Westar Energy, Inc. ("WR"), as the Designated Transmission Owner, to construct the Network Upgrade(s).

On September 6, 2017, SPP informed the Project Cost Working Group of this withdrawal.

Withdrawal of Upgrades

Previous NTC Number: 200379

Previous NTC Issue Date: 4/5/2016

Project ID: 31059

Project Name: Sub - Crawford - Neosho 69 kV Terminal Upgrades

Network Upgrade ID: 51563

Network Upgrade Name: Crawford - Neosho 69 kV Terminal Upgrades

Network Upgrade Description: Install any necessary terminal upgrades at Crawford and/or Neosho to increase the rating of the 69 kV line between the two substations.

Reason for Change: Westar upgraded Crawford – Neosho 69 kV ckt 1 during construction activities unrelated to this NTC on April 25, 2016. Therefore, the upgrade was not needed. (Per Commitment letter from Westar, dated July 1, 2016.)

SPP-NTC-200464


Withdrawal of Network Upgrade

This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in black ink that reads "Lanny Nickell". The signature is written in a cursive, flowing style.

Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Antoine Lucas - SPP
Jay Caspary - SPP
John Olsen - WR
Mo Awad - WR