

SPP
Notification to Construct

August 15, 2018

Mr. Wayman Smith
American Electric Power
212 E. 6th St.
Tulsa, OK 74119

RE: Withdrawal of Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Smith,

Southwest Power Pool, Inc. ("SPP") provides this withdrawal of a Notification to Construct ("NTC") to American Electric Power ("AEP").

On July 13, 2018, SPP informed the Project Cost Working Group of the withdrawal, per SPP Business Practice 7060 Section 7.1. On July 31, 2018, the SPP Board of Directors approved the withdrawal of the Network Upgrade(s) listed below.

Withdrawal of Upgrades

Previous NTC Number: 200246

Previous NTC Issue Date: 2/19/2014

Project ID: 30559

Project Name: Line - Chapel Hill REC - Welsh Reserve 138 kV Ckt 1

Network Upgrade ID: 50697

Network Upgrade Name: Chapel Hill REC - Welsh Reserve 138 kV Ckt 1 Rebuild

Network Upgrade Description: Rebuild 4.4-mile 138 kV line from Chapel Hill REC to Welsh Reserve.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2018 ITPNT and that withdrawal causes no adverse impacts to existing agreements.

Previous NTC Number: 200305

Previous NTC Issue Date: 9/30/2014

Project ID: 1083

Project Name: Line - Welsh Reserve - Wilkes 138 kV Ckt 1

Network Upgrade ID: 11423

Network Upgrade Name: Welsh Reserve - Wilkes 138 kV Ckt 1 Rebuild

Network Upgrade Description: Rebuild 23.7-mile 138 kV line from Welsh Reserve to

SPP-NTC-210503

Wilkes with 1926.9 ACSR/TW conductor. Upgrade switches at Welsh Reserve and Wilkes and wave traps, jumpers, CT ratios, and relay settings at Wilkes.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2018 ITPNT and that withdrawal causes no adverse impacts to existing agreements.


Withdrawal of Network Upgrade

AEP has been made aware of all Network Upgrades withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall change such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Jay Caspary - SPP
Bob Bradish - AEP
Richard Ross - AEP
Brian Johnson - AEP
Scott Rainbolt - AEP
Matt McGee - AEP
Evan Wilcox – AEP
Jim Jacoby – AEP