

**SPP
Notification to Construct**

August 17, 2018

Mr. Mike Risan
Basin Electric Power Cooperative
1717 E. Interstate Ave.
Bismarck, ND 58503

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Risan,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Basin Electric Power Cooperative ("BEPC"), as the Designated Transmission Owner, to construct the Network Upgrade(s).

On July 31, 2018, the SPP Board of Directors approved the Network Upgrade(s) listed below to be constructed as part of the 2018 Integrated Transmission Planning Near-Term ("ITPNT") Assessment.

New Network Upgrades

Project ID: 51295

Project Name: Line - Lewis - Richland 115kV Ckt 1

Need Date for Project: 6/1/2019

Estimated Cost for Project: \$105,000 (this project cost contains Network Upgrades not included in this NTC)

Network Upgrade ID: 72050

Network Upgrade Name: Lewis - Richland 115kV Ckt 1 (BEPC)

Network Upgrade Description: Adjust CT taps on Lewis to Richland to 1200/5.

Network Upgrade Owner: BEPC

MOPC Representative(s): David Raatz

TWG Representative: Matthew Stoltz

Categorization: Regional Reliability

Network Upgrade Specification: All elements and conductor must have at least an emergency rating of 154 MVA.

Network Upgrade Justification: Selected for 2018 ITPNT portfolio

Estimated Cost for Network Upgrade (current day dollars): \$5,000

Cost Allocation of the Network Upgrade: Base Plan

Estimated Cost Source: BEPC
Date of Estimated Cost: 4/11/2018

Commitment to Construct

Please provide to SPP a written commitment to construct the Network Upgrade(s) within 90 days of the date of this NTC, in addition to providing a construction schedule and an updated $\pm 20\%$ cost estimate, NTC Project Estimate, in the Standardized Cost Estimate Reporting Template for the Network Upgrade(s). Failure to provide a sufficient written commitment to construct as required by the SPP OATT could result in the Network Upgrade(s) being assigned to another entity.

Mitigation Plan

The Need Date represents the timing required for the Network Upgrade(s) to address the identified need. Your prompt attention is required for formulation and approval of any necessary mitigation plans for the Network Upgrade(s) included in the Network Upgrade(s) if the Need Date is not feasible. Additionally, if it is anticipated that the completion of any Network Upgrade will be delayed past the Need Date, SPP requires a mitigation plan be filed within 60 days of the determination of expected delays.

Notification of Commercial Operation

Please submit a notification of commercial operation for each listed Network Upgrade to SPP as soon as the Network Upgrade is complete and in-service. Please provide SPP with the actual costs of these Network Upgrades as soon as possible after completion of construction. This will facilitate the timely billing by SPP based on actual costs.

Notification of Progress

On an ongoing basis, please keep SPP advised of any inability on BEPC's part to complete the approved Network Upgrade(s). For project tracking, SPP requires BEPC to submit status updates of the Network Upgrade(s) quarterly in conjunction with the SPP Board of Directors meetings. However, BEPC shall also advise SPP of any inability to comply with the Project Schedule as soon as the inability becomes apparent.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

SPP-NTC-210492

Sincerely,



Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Jay Caspary - SPP
Matthew Stoltz - BEPC
David Raatz - BEPC