

SPP
Notification to Construct

August 17, 2018

Mr. Kalun Kelley
Western Farmers Electric Cooperative
701 NE 7th Street
Anadarko, OK 73005

RE: Withdrawal of Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Kelley,

Southwest Power Pool, Inc. ("SPP") provides this withdrawal of a Notification to Construct ("NTC") to Western Farmers Electric Cooperative ("WFEC").

On July 13, 2018, SPP informed the Project Cost Working Group of the withdrawal, per SPP Business Practice 7060 Section 7.1. On July 31, 2018, the SPP Board of Directors approved the withdrawal of the Network Upgrade(s) listed below.

Withdrawal of Upgrades

Previous NTC Number: 200397
Previous NTC Issue Date: 5/17/2016
Project ID: 31010
Project Name: Device - Blanchard 69 kV Cap Bank

Network Upgrade ID: 51455
Network Upgrade Name: Blanchard 69 kV Cap Bank
Network Upgrade Description: Install 9-MVAR capacitor bank at Blanchard 69 kV.
Reason for Change: SPP determined the Network Upgrade was no longer required in the 2018 ITPNT and that withdrawal causes no adverse impacts to existing agreements.

Previous NTC Number: 200397
Previous NTC Issue Date: 5/17/2016
Project ID: 31040
Project Name: Device - Ringwood 138 kV Cap Bank

Network Upgrade ID: 51525
Network Upgrade Name: Ringwood 138 kV Cap Bank
Network Upgrade Description: Install 7-MVAR capacitor bank at Ringwood 138 kV.

SPP-NTC-210500

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2018 ITPNT and that withdrawal causes no adverse impacts to existing agreements.

Previous NTC Number: 200397

Previous NTC Issue Date: 5/17/2016

Project ID: 31066

Project Name: Sub - Ringwood 138 kV Terminal Upgrades

Network Upgrade ID: 51485

Network Upgrade Name: Ringwood 138 kV Terminal Upgrades

Network Upgrade Description: Install 3-breaker ring bus at Ringwood to allow load to be moved from 69 kV to 138 kV.

Reason for Change: SPP determined the Network Upgrade was no longer required in the 2018 ITPNT and that withdrawal causes no adverse impacts to existing agreements.

Withdrawal of Network Upgrade

WFEC has been made aware of all Network Upgrades withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Jay Caspary - SPP
Ron Cunningham - WFEC
Carroll Reddick - WFEC