

SPP
Notification to Construct

August 17, 2018

Mr. Jeff Knottek
City Utilities of Springfield
301 East Central
Springfield, MO 65801-0551

RE: Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Knottek,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing City Utilities of Springfield ("CUS"), as the Designated Transmission Owner, to construct the Network Upgrade(s).

On July 31, 2018, the SPP Board of Directors approved the Network Upgrade(s) listed below to be constructed as part of the 2018 Integrated Transmission Planning Near-Term ("ITPNT") Assessment.

New Network Upgrades

Project ID: 51285

Project Name: Multi - Brookline 345kV

Need Date for Project: 6/1/2019

Estimated Cost for Project: \$4,175,203

Network Upgrade ID: 72037

Network Upgrade Name: Brookline 345kV Reactor

Network Upgrade Description: Install new 50 MVAR reactor at Brookline 345kV.

Network Upgrade Owner: CUS

MOPC Representative(s): Jeff Knottek

TWG Representative: John Boshears

Categorization: Regional Reliability

Network Upgrade Specification: Install new 50 MVAR reactor at Brookline 345kV.

Network Upgrade Justification: Selected for 2018 ITPNT portfolio

Estimated Cost for Network Upgrade (current day dollars): \$3,547,472

Cost Allocation of the Network Upgrade: Base Plan

Estimated Cost Source: CUS

Date of Estimated Cost: 4/13/2018

SPP-NTC-210493

Network Upgrade ID: 72038

Network Upgrade Name: Brookline 345kV Substation Expansion

Network Upgrade Description: Brookline 345kV Substation expansion to accommodate new 50MVAR reactor.

Network Upgrade Owner: CUS

MOPC Representative(s): Jeff Knottek

TWG Representative: John Boshears

Categorization: Regional Reliability

Network Upgrade Specification: All elements and conductor must have at least an emergency rating of 1130 MVA.

Network Upgrade Justification: Selected for 2018 ITPNT portfolio

Estimated Cost for Network Upgrade (current day dollars): \$627,731

Cost Allocation of the Network Upgrade: Base Plan

Estimated Cost Source: CUS

Date of Estimated Cost: 6/12/2018

Commitment to Construct

Please provide to SPP a written commitment to construct the Network Upgrade(s) within 90 days of the date of this NTC, in addition to providing a construction schedule and an updated $\pm 20\%$ cost estimate, NTC Project Estimate, in the Standardized Cost Estimate Reporting Template for the Network Upgrade(s). Failure to provide a sufficient written commitment to construct as required by the SPP OATT could result in the Network Upgrade(s) being assigned to another entity.

Mitigation Plan

The Need Date represents the timing required for the Network Upgrade(s) to address the identified need. Your prompt attention is required for formulation and approval of any necessary mitigation plans for the Network Upgrade(s) included in the Network Upgrade(s) if the Need Date is not feasible. Additionally, if it is anticipated that the completion of any Network Upgrade will be delayed past the Need Date, SPP requires a mitigation plan be filed within 60 days of the determination of expected delays.

Notification of Commercial Operation

Please submit a notification of commercial operation for each listed Network Upgrade to SPP as soon as the Network Upgrade is complete and in-service. Please provide SPP with the actual costs of these Network Upgrades as soon as possible after completion of construction. This will facilitate the timely billing by SPP based on actual costs.

Notification of Progress

On an ongoing basis, please keep SPP advised of any inability on CUS's part to complete the approved Network Upgrade(s). For project tracking, SPP requires CUS to submit status updates of the Network Upgrade(s) quarterly in conjunction with the SPP Board of Directors meetings.

SPP-NTC-210493

However, CUS shall also advise SPP of any inability to comply with the Project Schedule as soon as the inability becomes apparent.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this Project, and nothing in this NTC shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments regarding these instructions. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



Lanny Nickell

Vice President, Engineering

Phone: (501) 614-3232 • Fax: (501) 482-2022 • lnickell@spp.org

cc: Carl Monroe - SPP
Antoine Lucas - SPP
Jay Caspary - SPP
John Boshears - CUS
Jeff Knottek - CUS