

SPP-NTC-210590

**SPP
Notification to Construct**

November 23, 2020

Mrs. Katy Onnen
Evergy Missouri West, Inc.
801-A, P.O. Box 418679
Kansas City, MO 64141-9679

RE: Notification to Construct for Transmission Service Request resulting from Aggregate Transmission Service Study SPP-2020-AG1-AFS-3

Dear Mrs. Onnen,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Evergy Missouri West, Inc. ("EMW"), as the Designated Transmission Owner, to construct the Network Upgrades.

On November 9, 2020, SPP concluded that the project(s) is required on the EMW system to fulfill Transmission Service Requests as detailed in Aggregate Facility Study SPP-2020-AG1-AFS-3.

New Network Upgrades

Project ID: 91891

Project Name: Sub - Greenwood 161 kV Terminal Upgrades

Need Date for Project: 6/1/2021

Estimated In-Service Date: 12/31/2021

Estimated Cost for Project: \$800,000

Network Upgrade ID: 143183

Network Upgrade Name: Greenwood 161 kV Terminal Upgrades

Network Upgrade Description: Replace 2 breakers, relays at Greenwood 161 kV substation

Network Upgrade Owner: EMW

Categorization: Transmission Service

Network Upgrade Specification: All elements and conductor must have at least an emergency rating of 480 MVA.

SPP-NTC-210590

Network Upgrade Justification: SPP-2020-AG1-AFS-3
Estimated Cost for Network Upgrade (current day dollars): \$800,000
Cost Allocation of the Network Upgrade: Partial Base Plan Funding
Estimated Cost Source: EMW
Date of Estimated Cost: 10/14/2020

Project ID: 91892

Project Name: Sub - Pleasant Hill 161 kV and Lake Winnebago 161 kV Terminal Upgrades

Need Date for Project: 6/1/2021

Estimated In-Service Date: 12/31/2021

Estimated Cost for Project: \$430,000

Network Upgrade ID: 143184

Network Upgrade Name: Pleasant Hill 161kV and Lake Winnebago 161 kV Terminal Upgrades

Network Upgrade Description: Replace 2 breakers at Pleasant Hill 161 kV substation and replace 1 switch at Lake Winnebago 161 kV substation in order to increase the limit on the Pleasant Hill - Lake Winnebago 161 kV line.

Network Upgrade Owner: EMW

Categorization: Transmission Service

Network Upgrade Specification: All elements and conductor must have at least an emergency rating of 518 MVA.

Network Upgrade Justification: SPP-2020-AG1-AFS-3

Estimated Cost for Network Upgrade (current day dollars): \$430,000

Cost Allocation of the Network Upgrade: Partial Base Plan Funding

Estimated Cost Source: EMW

Date of Estimated Cost: 10/14/2020

Commitment to Construct

Please provide to SPP a written commitment to construct the Network Upgrade(s) within 90 days of the date of this Notification to Construct, in addition to providing a construction schedule and an updated $\pm 20\%$ cost estimate, NTC Project Estimate, in the Standardized Cost Estimate Reporting Template for the Network Upgrade(s). Failure to provide a written commitment to construct as required by the SPP OATT could result in the Network Upgrade(s) being assigned to another entity.

Mitigation Plan

The Estimated In-Service Date represents the timing required for the Network Upgrade(s) to address the identified need. Your prompt attention is required for formulation and approval of any necessary mitigation plans for the Network Upgrade(s) included in the Network Upgrades(s) if the Estimated In-Service Date is not feasible. Additionally, if it is anticipated that the completion of any Network Upgrade will be delayed past the Estimated In-Service Date, SPP

SPP-NTC-210590

requires a mitigation plan be filed within 60 days of determination of expected delays.

Notification of Commercial Operation

Please submit a notification of commercial operation for each listed Network Upgrade to SPP as soon as the Network Upgrade is complete and in-service. Please provide SPP with the actual costs of these Network Upgrades as soon as possible after completion of construction. This will facilitate the timely billing by SPP based on actual costs.

Notification of Progress

On an ongoing basis, please keep SPP advised of any inability on EMW 's part to complete the approved Network Upgrade(s). For project tracking, SPP requires EMW to submit status updates of the Network Upgrade(s) quarterly in conjunction with the SPP Board of Directors meetings. However, EMW shall also advise SPP of any inability to comply with the Project(s) Schedule as the inability becomes apparent.

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this project(s) and nothing in this letter shall carry such terms and conditions.

Don't hesitate to contact me if you have questions or comments about these requests. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,

A handwritten signature in blue ink, appearing to read "Antoine Lucas", is positioned above the typed name.

Antoine Lucas
Vice President, Engineering
Phone: (501) 614-3382 • Fax: (501) 482-2022 • alucas@spp.org

cc: Lanny Nickell - SPP
Casey Cathey - SPP
David Kelley - SPP
Denise Buffington - EMW
Mo Awad - EMW
Derek Brown - EMW