

SPP
Notification to Construct

March 16, 2023

Mr. Kalun Kelley
Western Farmers Electric Cooperative
701 NE 7th Street
Anadarko, OK 73005

RE: Withdrawal of Notification to Construct Approved Reliability Network Upgrades

Dear Mr. Kelley,

Pursuant to Section 3.3 of the Southwest Power Pool, Inc. ("SPP") Membership Agreement and Attachments O and Y of the SPP Open Access Transmission Tariff ("OATT"), SPP provides this Notification to Construct ("NTC") directing Western Farmers Electric Cooperative ("WFEC"), as the Designated Transmission Owner, to construct the Network Upgrades.

SPP concluded that the Network Upgrade listed below should be withdrawn and informed the appropriate organizational groups of the withdrawal in accordance SPP Business Practice 7060 Section 7.1. On May 31, 2019, SPP received executed Transmission Service Agreement(s) revised to remove requirement of Network Upgrade(s) associated with DPA-2012-151,154,161,218,243.

Withdrawal of Upgrades

Previous NTC Number: 200200

Previous NTC Issue Date: 3/1/2013

Project ID: 30491

Project Name: Device - Hazelton 69 kV

Network Upgrade ID: 50600

Network Upgrade Name: Hazelton 69 kV Capacitor

Network Upgrade Description: Install two 4.8 MVAR capacitors at Hazelton 69 kV for total of 9.6 MVAR.

Reason for Change: Hazelton 69 kV is not a qualified transmission facility per Attachment AI, Board approval 1/31/2023

Withdrawal of Network Upgrade

WFEC has been made aware of all Network Upgrades withdrawn through the expansion plan process. This letter is the formal notification to stop any further work on this Network Upgrade(s), collect any cost associated with the Network Upgrade(s), and provide this information to SPP.

SPP-NTC-210720

All terms and conditions of the SPP OATT and the SPP Membership Agreement shall apply to this project(s), and nothing in this letter shall vary such terms and conditions.

Don't hesitate to contact me if you have questions or comments about these requests. Thank you for the important role that you play in maintaining the reliability of our electric grid.

Sincerely,



David Kelley
Vice President, Engineering
Phone: (501) 688-1671 • Fax: (501) 482-2022 • dkelley@spp.org

cc: Lanny Nickell - SPP
Casey Cathey - SPP
Matt Caves - WFEC
John Turner - WFEC
Dave Sonntag - WFEC